



Notified Body No. 0370



No. **0370-CPR-1182**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 17: SHORT-CIRCUIT ISOLATORS

ISOLATORS OF THE ADDRESSABLE SYSTEM. MODELS:

- **MAD-490** (SIMPLE VOLTAGE AUTONOMOUS SHORT CIRCUIT ADDRESSABLE ISOLATOR)
- **MAD-491** (SIMPLE VOLTAGE AUTONOMOUS SHORT CIRCUIT ADDRESSABLE ISOLATOR)

Place on the market under the name of:

DETN OV SECURITY, S.L.

C/ DE LA CIÈNCIA, 30
08840 VILADECANS (BARCELONA - SPAIN)

And produced in the manufacturing plant:

C/ DE LA CIÈNCIA, 30
08840 VILADECANS (BARCELONA - SPAIN)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 10th June 2011 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 17th July 2020.

The monitoring assessment will be done before 30th September 2021

Bellaterra, 17th July 2020


Applus⁺
LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the number of certificate.

You can check the validity of this certificate into our website at: <https://apps.applus.com/microsites/microsites/FECIP/login>



0370-CPR-1182

Annex according to **EN 54-17, EN 54-17:2005/AC:2007**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Compliance	4.1	PASS
Integral status indication	4.2	PASS
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	PASS
On-site adjustments	4.6	NA
Marking	4.7	PASS
Data	4.8	PASS
Additional requirements for software controlled short-circuit isolators	4.9	NA
Reproducibility	5.2	PASS
Variation in supply voltage	5.3	PASS
Dry heat (operational)	5.4	PASS
Cold (operational)	5.5	PASS
Damp heat, cyclic (operational)	5.6	PASS
Damp heat, steady state (endurance)	5.7	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	PASS
Shock (operational)	5.9	PASS
Impact (operational)	5.10	PASS
Vibration, sinusoidal (operational)	5.11	PASS
Vibration, sinusoidal (endurance))	5.12	PASS
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	PASS

PASS; NPD = No Performance Determined, NA = Not Apply